

# MET LABORATORIES, INC.

## CERTIFICATION RECORD



The applicant named below has been authorized by MET Laboratories, Inc. to represent the product(s) listed in this record as "MET Certified" and to mark this/these product(s) according to the terms and conditions of the MET Mark Utilization Agreement, MET Listing Reports, and the applicable marking agreements. Only the product(s) bearing the MET Mark and under a follow-up service are considered to be included in the MET Certification program.

FILE NUMBER:

E112404

APPROVAL DATE:

April 11, 2005

REVISED:

-

PRODUCT(S)	MODEL(S)	ELECTRICAL RATINGS
See Level Illuminator Power Supply	ISPS-6-1	Input:115 VAC, 50/60 Hz, 150 mA max Output: Voc = 8.61 VDC, It = 1.511 mA

STANDARD NUMBER	STANDARD TITLE	EDITION
UL60950-1/ CSA C22.2 No. 60950-1	Safety of Information Technology Equipment	First
UL913	Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations	Sixth
CSA C22.2 No. 157-92	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations	Reaffirmed 1997
UL1203	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations	Third
CSA C22.2 No. 30-M1986	Explosion-Proof Enclosures for Use in Class I Hazardous Locations.	Reaffirmed 1999

MET LABORATORIES, INC. requires that any and all changes proposed in the previously identified product(s), that affects the information contained in the above referenced listing report, must be submitted to MET for evaluation prior to implementation to assure continued MET Certification status.

The above identified product(s) has/have been submitted by the applicant:

**APPLICANT:**

Quest-Tec Solutions  
4003-D Greenbriar  
Stafford, TX 77477 USA

The covered products shall be subjected to semi annual follow-up inspections to ensure that the Certified product(s) are identical to the representative product sample evaluated by MET LABORATORIES, INC. and that all manufacturer's responsibilities are being fulfilled as specified in the MANUFACTURING RESPONSIBILITY section of the Certification report.

Igor Kekovski  
Assistant Technical Manager  
Safety Laboratory

Rick Cooper  
Director of Laboratory Operations,  
Safety Laboratory



MET Laboratories, Inc. is accredited by OSHA and the Standards Council of Canada.  
The Nation's First Nationally Recognized Testing Laboratory

**NRTL**